

# **Compliance Statement**

No. 2023-078

Data communication cable, Category 7

#### Company

LW Electronic GmbH Obere Seegasse 33 69124 Heidelberg Germany

#### Product description

Screened cable (S/FTP) characterised up to 1000 MHz\* Horizontal floor wiring cable, 100  $\Omega$ 4 individually foil screened twisted pairs with overall braid screen Flame retardant, halogen free

#### **Product identification**

S/FTP CAT7 4P 23AWG LSZH LW-CAT7-1000MHZ-xxM

## Generic cabling and cabling components standards - Category 7 cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-4-1:2013

### Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

**Technical report** 12322129, DANAK-19/23231 **EC Cabling product ID** 7052 **CS valid until** 1 February 2024

\*Transmission parameters comply with extended Cat. 7 limits up to 1000 MHz.

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 1 February 2023

Lars Lindskov Pedersen Test Manager

Lindska Pedana

Domin anderen

Dennis Andersen Head of Department



FORCE Technology Venlighedsvej 4 2970 Hørsholm Denmark Tel. +45 43 25 14 00 Jan.forcetechnology.com